



Ref. Certif. No.

SE-90568

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Residual current operated circuit-breaker with integral overcurrent protection (RCBO's)
Name and address of the applicant	Zhejiang ETEK Electrical Technology Co., Ltd. No. 288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang Province, P.R.China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	Un= 230/240V~(1P+N), 50/60Hz In= 6, 10, 16, 20, 25, 32, 40A, B-&C-type IΔn= 0,01, 0,03, 0,1, 0,3A, type-A&-AC Ics= Icn= 6000A, Energy limiting class 3
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	EKL2-40
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 61009-1:2010+A1+A2 IEC 61009-2-2:1991
As shown in the Test Report Ref. No. which forms part of this Certificate	180100615SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB  
Box 1103  
SE-164 22 Kista, Sweden  
Int +46 8 750 00 00

Date: 24 April 2018



Signature:

Bo Berglöf