

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Name and address of the applicant

Zhejiang ETEK Electrical technology Co., Ltd.
No. 288 Wei 17th Road, Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zhejiang,
China

Name and address of the manufacturer

Hangzhou Taimu Electrical Co., Ltd.
No. 157 Longchuanwu Road, Yuhang Economic Development
Area, Hangzhou,
China

Name and address of the factory

Same as manufacturer

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Un= 240/415V~ (1P), 415V~ (2P, 3P, 4P), 50/60Hz
In= 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A; B-, C- and D-
Type
Icn= Ics= 6000A, Energy limiting class 3 (Only for B-, C- Type)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

EKM2-63

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

210302558SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden**intertek**

Signature:



Leif Mattsson

Date: 11 May, 2021