

Certificate

for European Product Safety

Reference No. 1809640

Residual current operated circuit-breaker with integral overcurrent protection (RCBO's)

Type designation

EKL2-40

Certificate holder

Zhejiang ETEK Electrical Technology Co., Ltd.

No. 288 Wei 17th Road, Yueging Economic Development Zone,

Yueqing, Wenzhou, Zhejiang Province

P.R. China

The product complies with the standard(s)

EN 61009-1:2012+A1+A2+A11+A12

Date of expiry

24 April 2023

EU Directive information

According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking

according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix.

Certification Body

Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed

Date

24 April 2018 Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.





Reference No. 1809640

Technical data

Type designation:

EKL2-40

Rated voltage (V):

230/240V~

Frequency (Hz):

50/60Hz

Rated current (A):

6, 10, 16, 20, 25, 32, 40A

Rated Residual OperatingCurrent (mA):

10, 30, 100, 300mA

IP-Class:

IP20

Poles No:

1P+N

BRAND name:

ET3K

Product information:

B- & C-type, type-A&-AC

I_{cs}= I_{cn}= 6000A, Energy limiting class 3

Manufacturing site(s)

Zhejiang ETEK Electrical Technology Co., Ltd.

No. 288 Wei 17th Road, Yueqing Economic Development Zone,

Yueqing, Wenzhou, Zhejiang Province,

P.R. China

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Certification Body

Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed

Po Porgiës

Date 24 April 2018

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.