

  
Intertek **CERTIFICATE**  
**FOR EUROPEAN PRODUCT SAFETY**

Reference No. SE-S-2200084

# Low-voltage switchgear and controlgear - part 3: Switch-disconnectors

<b>Type designation:</b>	EKD2-125
<b>Certificate holder:</b>	Zhejiang ETEK Electrical technology Co., Ltd. No. 288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang China
<b>The product complies with the standard(s):</b>	EN IEC 60947-3:2021
<b>Date of expiry:</b>	24 January, 2027
<b>EU Directive information:</b>	According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

**Intertek**

Additional information in Appendix

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**




**Date:** 24 January, 2022

Quan Li

## APPENDIX:

Reference No. SE-S-2200084

### Technical Data:

Type designation	EKD2-125
Rated voltage (V)	230/240V~ (1P), 400/415V~ (2P, 3P, 4P)
Rated current (A)	25, 32, 40, 50, 63, 80, 100, 125A
Frequency (Hz)	50/60
IP-Class	20
Poles No.	1P, 2P, 3P, 4P
Trademark	
Test Report	211102689SHA-001
Product information	Cat. AC-22A, Ui=500V, Uimp=6kV, Icw=2000A/1s, Icm=3000A

### Manufacturing Sites:


ZHEJIANG ETEK Electrical technology Co., Ltd.  
No. 288 Wei 17th Road, Yueqing Economic Development Zone,  
Yueqing, Wenzhou, Zhejiang China

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**



**Date:** 24 January, 2022

Quan Li

**Intertek**