

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50487537

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
Q.J.B

Unser Zeichen *Our Reference*
01-DY-60429104 001

Ausstellungsdatum *Date of Issue*
09.12.2020 (day/mo/yr)

Genehmigungsinhaber *License Holder*

Zhejiang ETEK Electrical Technology Co., Ltd.
NO.288 Wei 17th Road,
Yueqing Economic Development Zone,
Yueqing, Wenzhou
Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*

Zhejiang ETEK Electrical Technology Co., Ltd.
NO.288 Wei 17th Road,
Yueqing Economic Development Zone,
Yueqing, Wenzhou
Zhejiang
P.R. China

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111232668

Geprüft nach *Tested acc. to*

EN 61008-1:2012+A1+A2+A11+A12
EN 61008-2-1:1994+A11

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

Lizenzentgelte - Einheit *License Fee - Unit*

Earth Leakage Circuit Breaker (RCCBs)

Type Designation	: 1) EKL6-100 2) EKL6-100H	8
Number of Poles	: 2P(1P+N) 4P(3P+N)	
Rated Operational Voltage (Ue)	: 230/240V 400/415V	
Nature of Supply	: AC 50/60Hz	
Rated Current (In)	: 16/25/32/40/63/80/100A	
Behavior in Presence of d.c.		
Components	: Type A or Type AC	
Time-delay	: General type	
Rated Residual Operating Current	: 30/100/300mA	
Rated Making and Breaking Capacity		
Capacity	: 500A or 10In	
Rated Residual Making and Breaking Capacity	: 500A or 10In	
Rated Conditional Short-circuit Current	: 1) 6,0kA 2) 10,0kA	
Rated Conditional Residual Short-circuit Current	: 1) 6,0kA 2) 10,0kA	
Ambient Air Temperature	: -25°C to +40°C	
Rated Insulation Voltage	: AC 500V	
Impulse Withstand Voltage	: 4,0kV	
Suitability of Isolation	: Yes	

ANLAGE (Appendix): 1

8

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Zhejiang ETEK Electrical Technology
Co.,Ltd.
Qi Jibin

Date : 09.12.2020
Our ref. : DY 01
Your ref.: Q.J.B

NO.288 Wei 17th Road,
Yueqing Economic Development Zone,
Yueqing, Wenzhou
Zhejiang
P.R. China

Ref : R TÜV-Mark Approval

Type of Equipment : RCCBs
Model Designation : See Certificate
Certificate No. : R 50487537 0001
Report No. : 60429104 001

Dear Qi Jibin,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body


Kenny Shi

cc: Zhejiang ETEK Electrical Technology

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询