

# Zertifikat

# Certificate



<b>Zertifikat Nr. Certificate No.</b> R 50548606	<b>Blatt Sheet</b> 0001		
<b>Ihr Zeichen Client Reference</b> Z.Y.	<b>Unser Zeichen Our Reference</b> 01-ZWC-CN2264T4 005	<b>Ausstellungsdatum Date of Issue</b> 23.06.2022	<b>Date of Issue</b> (day/mo/yr)

<b>Genehmigungsinhaber License Holder</b> Zhejiang ETEK Electrical Technology Co.,Ltd. NO.288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou Zhejiang P.R. China	<b>Fertigungsstätte Manufacturing Plant</b> 040-0002179822
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------

**Prüfzeichen Test Mark**



Type Approved  
Safety  
Regular Production  
Surveillance

www.tuv.com  
ID 1111255843

**Geprüft nach Tested acc. to**  
EN 61643-31:2019  
IEC 61643-31:2018

<b>Zertifiziertes Produkt (Geräteidentifikation)</b> <i>Certified Product (Product Identification)</i>	<b>Lizenzentgelte - Einheit</b> <i>License Fee - Unit</i>
-----------------------------------------------------------------------------------------------------------	--------------------------------------------------------------

Surge Protector (Surge Protective Device for PV application)

Type Designation : EKU5-T1+T2-40PV (ETEK)	6
Ucpv : 1500 V DC(+ to -, +/- to PE)	
Up : 5.2 kV	
Iimp(10/350 ) : 6.25 kA	
In : 20 kA	
Iscpv : 10 A	
Imax : 40 kA	
Type of SPD : Type 1 + Type 2	
Itotal : 12.5 kA(10/350 µs); 40 kA(8/20 µs)	
Location : Indoor	
Temperature : Extended range	

6

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



**Zertifizierungsstelle**

*Yang Yongming*  
**Yongming Yang**

**TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg**  
http://www.tuv.com/safety E-mail: markcheck@tuv.com  
Fax: +49 221 806-3935



Zhejiang ETEK Electrical Technology  
Co., Ltd.  
Zhao Yun

Date : 23.06.2022  
Our ref. : ZWC 01  
Your ref.: Z.Y.

NO.288 Wei 17th Road,  
Yueqing Economic Development Zone,  
Yueqing, Wenzhou  
Zhejiang  
P.R. China

**Ref : R TÜV-Mark Approval**

Type of Equipment : Surge Protective Device for PV application  
Model Designation : See Certificate  
Certificate No. : R 50548606 0001  
Report No. : CN2264T4 005

Dear Zhao Yun,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.

If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,

Certification Body



Yongming Yang

cc: Zhejiang ETEK Electrical Technology

Enclosure

证书的详细资料请登陆[www.certipedia.com](http://www.certipedia.com)查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询